CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEEDING. PUBLISHING MATERIALS LISTING PROCEDUM.

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0085:172 Page 1 of 1

CATEGORY: Control Unit (Non-High Rise)

LISTEE: ADT, 4128 North Freeway Blvd., Sacramento, CA 95834

Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942*

DESIGN: Model **Unimode-200** fire alarm control unit. Local, auxiliary, remote station, proprietary

(protective premises). Refer to listee's data sheet for additional detailed product description

and operational considerations. System components:

Unimode-200 Main Board RTM-8F Relay Module

ZDM-16F Annunciator Module

PIM-24 Printer/PC Interface Module

ADT-LCD-40, ADT-LCD-40L Remote Annunciator

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and

indicating devices. This control unit can generate a distinctive temporal code pattern fire alarm signal as required per NFPA 72, 1996 Edition. Refer to listee's Installation instructions

Manual for details.

NOTE: 1. Software options and other non-fire functions **not** examined.

2. For Fire Alarm Verification Feature (delay of fire alarm), the maximum

Retard/Reset/Restart shall not exceed 30 seconds.

XLF: 7165-0075:158

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 8, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager